

TAMILNADU GENERATION AND DISTRIBUTION CORPORATION LTD

From
Er.M.Satheeskumar,B.E.,
Assistant Executive Engineer,
MRT, Villupuram.

To
The Superintending Engineer,
VEDC, Villupuram.

Lr.No.AEE/MRT/VPM/F-SS/D. 327 /2015 dt 26.08.2015,

Sir,

Sub: ElecY – VEDC/VPM – supply of 8 nos. Static/Numeric Over Current and earth Fault Relays (Make: VOLTECH) – performance report – submission of – regarding.

Ref: 1.Lr.No.SE/VEDC/AEE/MM/AE/PO.No.31/12 dt 31.08.2012.

2. Voltech relay company Ref No. VMCL?TNEB/VP/PC/2015-16 dt 18.08.2015.

8 nos. Voltech Manufacturing Company Ltd make Static/Numeric Over Current and Erath fault relays (Type VN 100R) have been commissioned for the following Substation.

Sl.No.	Name of the SS	Date of Commissioning
1	Murukkery 110/33-11 KV SS	29.11.2012
2	Valavanur 110/22 KV SS	12.10.2012
3	Thiruvonnainallur 110/22KV SS	11.12.2012
4	Kallakurichi 110/22KV SS	06.12.2012
5	Ariyalur 110/22KV SS	03.12.2012
6	Gingee 110/33-11 KV SS	19.11.2012
7	Kanjanur 110/22KV SS	19.12.2012
8	Tindivanam 110/33-11 KV SS	17.11.2012

The performance of the relays were found satisfactory from the date of commissioning.

[Signature]
26.08.2015
ASSISTANT EXECUTIVE ENGINEER
MRT / VILLUPURAM

Copy Submitted to the Superintending Engineer / KEDC / Kallakurichi.

Copy Submitted to Voltech Manufacturing Company Ltd, Relay Division,
No.132,133,134, Sree Kumaran Nagar, Kundrathur Main Road, Kvur, Chennai-600122.