



TANGEDCO

From
Er. S.Rajarajan , B.E.,
Superintending Engineer,
CEDC/North,
Chennai -2.

To
M/s Voltech Manufacturing Company Ltd.,
Relay Division,
No.132,133,134,
Sree Kumaran Nagar,
Kundrathur Main Road,
Kovur,Chennai -600 128.

Lr. No. SE/CEDC/N/AEE/MM/AE/F.MRT/D. 1292/15 dt. 13 /08/2015.

Sir,

Sub : CEDC/North – Numerical Over current and earth fault relay
(Type –VN100R) – performance report - Regarding.

Ref : Your Letter Ref: VMCL/TNEB/SP/PC/2015-16 dt 04.05.15

With reference to the above, One No. sample of three phase Numerical Over current and Earth fault relay (Type-VN100R, SI.No. VMC 014-4648) supplied by you during the year 2014 was commissioned at 11 KV Muthamizh nagar feeder off 33/11 KV IPL sub-station, Chennai and the performance is found to be satisfactory.

S. R. J.
SUPERINTENDING ENGINEER,
CEDC/NORTH

2/3
SUPERINTENDING ENGINEER
Chennai Electricity Distribution Circle/North
Chennai - 600 002.

Copy to the Exe.Engineer/MRT/CEDC/North