



WEST BENGAL STATE ELECTRICITY DISTRIBUTION CO. LTD.

(A Government of West Bengal Enterprise)

Office of the Chief Engineer, Project - I

2nd Floor, "B" Block, Bidyut Bhavan, Block-DJ, Sector-II, Bidhannagar, Kolkata - 700 091

Telephone: (033) 2358 9809, Fax: (033) 2337 2635, E-mail: cedistproject@gmail.com.

Memo No. CE/Project - I/88/6786

Date: 14.05.15

To,

M/s Larsen & Toubro Ltd.

11th Floor, Tower-2,

Godrej Waterside Building,

Sector-V, Salt Lake City,

Kolkata-700091.

- Sub:** Approval of drawing/GTP of 3.15 MVA & 6.3 MVA Power Transformer (Make:- M/s Voltech Manufacturing Company Works) for works to be executed at 13 Towns under R-APDRP (Part-B7) projects.
- Ref:** i) LOA No. CE (Dist. Project)/R-APDRP/Part-B7/13-Towns/PK-C5/Supply/5388 & Erection/5389 dt.25.08.14
ii) Your Memo no. LTCD/KKRO/PT&D/PP/2015-0038 dt. 07.03.15.
iii) Our memo no. CE/DP/88/6483 dated 18.03.15
iv) Your memo no. LTCD/KKRO/PT&D/PP/2015-0079 dt. 08.04.15.

Dear Sir,

With reference to above, please find the related drawing / GTP of 6.3 MVA (with OLG on load TC) & 3.15 MVA (with offload TC) Power Transformer (Make:- M/s Voltech Manufacturing Company Works) for works to be executed at 13 Towns under R-APDRP (Part-B7) projects, is hereby accorded, subject to following corrections & modifications:

- 1) As per provision of WBSEDCL practice, Turret is to be provided along with equalizing pipe i.r.o. HV bushings of both 6.3 MVA & 3.15 Transformer.
- 2) Ladder with safety lock is to be provided in the 6.3 MVA transformer
- 3) Mentioned 3.15 MVA & 6.3 MVA Power Transformers should be designed, manufactured and tested as per provision in relevant Indian Standards and furnished technical specification of WBSEDCL with simultaneous incorporation of corrections/additions/modifications as noted in the GTP & related pages in 'RED INK'.

Also you are requested to arrange for submission of modified drawings for our final acceptance & records.

Encl: As stated

Yours faithfully,

(D. Choudhury)

Chief Engineer, Project-I